



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Honeymoon Bay Heights  
PO Box 223  
Freeland, WA 98249

Reference Number: 18-09391  
Project: Bacteria

System Name: HONEYMOON BAY HTS.PROP.OWNERS ASSN  
System ID Number: 39880  
DOH Source Number: 01  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: Guest Bath  
County: Island  
Sampled By: R L Duffy  
Sampler Phone:

Repeat Sample Number:  
Lab Number: 164-19741  
Field ID: HBHPOA  
Date Collected: 3/20/18 08:50  
Date Received: 3/20/18  
Date Set: 3/20/18 17:27  
Date Analyzed: 3/21/18 12:54  
Report Date: 3/21/18  
Comment:  
Approved By: ckk,jfh

Authorized by:

Ceann K Knox  
Lab Manager, Bellingham

DOH#	PARAMETER	RESULT	Qualifier	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>		per 100mL	jma	SM9223 B	m_180320b	
3	E. COLI	<b>Absent</b>		per 100mL		SM9223 B	m_180320b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: [http://www.skagitcounty.net/drinkingwater\\_](http://www.skagitcounty.net/drinkingwater_) or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**  
If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.  
\*If data qualifiers are present, see accompanying Qualifier Definition report.